

TENDER REFERENCE NO.: KK/73/2026/HTD

**MINISTRY OF HEALTH
NEGARA BRUNEI DARUSSALAM**

**TO REPLACE THE REVERSE OSMOSIS MEMBRANE AND
REBEDDING MULTI MEDIA FOR REVERSE OSMOSIS
WATER TREATMENT SYSTEM AT WARD 17 AND WARD 18
(2ND FLOOR) RIPAS HOSPITAL, MINISTRY OF HEALTH**

TENDER FEES : \$10.00

RECEIPT NO. :

CLOSING DATE : 05th May 2026

TIME : 2.00 PM

FOA :

**THE CHAIRMAN
MINI TENDER BOARD, TENDER BOX
GROUND FLOOR, MINISTRY OF HEALTH
COMMONWEALTH DRIVE
BANDAR SERI BEGAWAN BB3910
NEGARA BRUNEI DARUSSALAM**

(CLUSTERING)

SECTION 2

SPECIFICATIONS AND REQUIREMENTS

TENDER REFERENCE NO.: KK/73/2026/HTD

INVITATION TO TENDER

TO REPLACE THE REVERSE OSMOSIS MEMBRANE AND REBEDDING MULTI MEDIA FOR REVERSE OSMOSIS WATER TREATMENT SYSTEM AT WARD 17 AND WARD 18 (2ND FLOOR) RIPAS HOSPITAL, MINISTRY OF HEALTH

SCOPE OF WORK

1. INSTALL AND REPLACE OF NEW REVERSE OSMOSIS (RO) MEMBRANE FOR RO SYSTEM (6 UNITS)
2. REMOVE AND REPLACE WITH NEW MULTI MEDIA FOR SEDIMENT FILTERS (2 UNITS)
3. REMOVE AND REPLACE WITH NEW MULTI MEDIA FOR CARBON FILTERS (4 UNITS)
4. REMOVE AND REPLACE WITH NEW MULTI MEDIA FOR SOFTENER FILTERS (4 UNITS)
5. TESTING AND RUNNING SYSTEM OF NEW INSTALLED MEMBRANES AND MULTI MEDIAS
6. WORK HAVE TO BE DONE ONLY DURING WEEKEND

NO.	SPAREPART	PART NUMBER	QUANTITY
1	Sediment Filter Media (Volume 135 litres)	AM-1665 S-MM	2
2	Carbon Filter Media (Volume 135 litres)	AM-1665 C-MM	4
3	Softener Filter Media (Volume 135 litres)	AM-1665 SO-MM	4
4	RO Membrane	AM-146-M-8040	6

SECTION 3
TENDER FORM

To:

TENDER REFERENCE NO.: KK/73/2026/HTD

INVITATION TO TENDER
TO REPLACE THE REVERSE OSMOSIS MEMBRANE AND REBEDDING MULTI MEDIA FOR
REVERSE OSMOSIS WATER TREATMENT SYSTEM AT WARD 17 AND WARD 18 (2ND FLOOR)
RIPAS HOSPITAL, MINISTRY OF HEALTH

DELIVERY PERIOD	
------------------------	--

SCOPE OF WORK	PRICE (B\$)																				
<p>SCOPE OF WORK</p> <ol style="list-style-type: none"> 1. INSTALL AND REPLACE OF NEW REVERSE OSMOSIS (RO) MEMBRANE FOR RO SYSTEM (6 UNITS) 2. REMOVE AND REPLACE WITH NEW MULTI MEDIA FOR SEDIMENT FILTERS (2 UNITS) 3. REMOVE AND REPLACE WITH NEW MULTI MEDIA FOR CARBON FILTERS (4 UNITS) 4. REMOVE AND REPLACE WITH NEW MULTI MEDIA FOR SOFTENER FILTERS (4 UNITS) 5. TESTING AND RUNNING SYSTEM OF NEW INSTALLED MEMBRANES AND MULTI MEDIAS 6. WORK HAVE TO BE DONE ONLY DURING WEEKEND 																					
<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 10%; text-align: center;">NO.</th> <th style="width: 30%; text-align: center;">SPAREPART</th> <th style="width: 20%; text-align: center;">PART NUMBER</th> <th style="width: 40%; text-align: center;">QUANTITY</th> </tr> </thead> <tbody> <tr> <td style="text-align: center;">1</td> <td>Sediment Filter Media (Volume 135 litres)</td> <td style="text-align: center;">AM-1665 S-MM</td> <td style="text-align: center;">2</td> </tr> <tr> <td style="text-align: center;">2</td> <td>Carbon Filter Media (Volume 135 litres)</td> <td style="text-align: center;">AM-1665 C-MM</td> <td style="text-align: center;">4</td> </tr> <tr> <td style="text-align: center;">3</td> <td>Softener Filter Media (Volume 135 litres)</td> <td style="text-align: center;">AM-1665 SO-MM</td> <td style="text-align: center;">4</td> </tr> <tr> <td style="text-align: center;">4</td> <td>RO Membrane</td> <td style="text-align: center;">AM-146-M-8040</td> <td style="text-align: center;">6</td> </tr> </tbody> </table>	NO.	SPAREPART	PART NUMBER	QUANTITY	1	Sediment Filter Media (Volume 135 litres)	AM-1665 S-MM	2	2	Carbon Filter Media (Volume 135 litres)	AM-1665 C-MM	4	3	Softener Filter Media (Volume 135 litres)	AM-1665 SO-MM	4	4	RO Membrane	AM-146-M-8040	6	
NO.	SPAREPART	PART NUMBER	QUANTITY																		
1	Sediment Filter Media (Volume 135 litres)	AM-1665 S-MM	2																		
2	Carbon Filter Media (Volume 135 litres)	AM-1665 C-MM	4																		
3	Softener Filter Media (Volume 135 litres)	AM-1665 SO-MM	4																		
4	RO Membrane	AM-146-M-8040	6																		
TOTAL PRICE (B\$)																					