TAWARAN SEBUTHARGA
JABATAN PERKHIDMATAN KESIHATAN

Rujukan Tawaran: **36/QTN/JPK/2026**

Nama Tawaran:

SUPPLY, DELIVERY, SERVICE AND INSTALLATION OF THIRTY-TWO (32) UNITS OF FILTER CARTRIDGE FOR LUX BLONDAL AIR PURIFIER AT VARIOUS HEALTH CENTRES, HEALTH SERVICES DEPARTMENT, MINISTRY OF HEALTH

SPECIFICATIONS	
STANDARD FEATURES	SUPPLY AND INSTALL THIRTY-TWO (32) UNITS OF FILTER CARTRIDGE FOR LUX BLONDAL AIR PURIFIER
	THE SCOPE OF WORK THAT ARE ASSIGNED SHOULD BE DONE BY TRAINED SERVICE PERSONEL WITH PROPER PROCEDURE AND WEARING PROPER PPE FOR SAFETY AND INFECTION CONTROL PURPOSES.
	TO SERVICE/REPLACE PRE-FILTER
	TO INSTALL NEW HEPAFILTER
	AUTHENTIC HEPAFILTER ORIGINALLY FROM LUX BLONDAL
	TO CARRYOUT TESTING AIR PURIFIER AFTER INSTALLATION OF HEPAFILTER CARTRIDGE
	TO VERIFY AIR PURIFIER WORKING NORMALLY

Please state:

- Brand/ Model
- Country of origin
- Price per unit
- Total price
- Delivery period
- Price Validity
- Sample & Brochure
- Warranty

Location List Of Lux Blondal Air Purifier

NOS	FACILITY/HEALTH CENTRE NAME	LOCATION (PHC/MCH/CLINIC)	BRAND OF AIR PURIFIER	BME NO.	SERIAL NO.
1	Berakas HC	PHC	Lux Blondal	069844	NO SERIAL NO
2	Berakas HC	PHC	Lux Blondal	069840	NO SERIAL NO
3	PAPHMWHB Gadong HC	Dental clinic	Lux Blondal	25719	tidak ada (Bilik4)
4	PAPHMWHB Gadong HC	Dental clinic	Lux Blondal	25717	tidak ada (Bilik1)
5	PAPHMWHB Gadong HC	Dental clinic	Lux Blondal	25718	tidak ada (Bilik 2)
6	PAPHMWHB Gadong HC	Dental clinic	Lux Blondal	25721	tidak ada (Bilik5)
7	PAPHMWHB Gadong HC	Dental clinic	Lux Blondal	25720	tidak ada (Bilik6)
8	PAPHMWHB Gadong HC	DIETATION ROOM	Lux Blondal	TIDAK ADA	VT1804000239
9	PAPHMWHB Gadong HC	PHC	Lux Blondal	NIL	VT1804000239
10	Sg Kelugos HC	PHC	Lux Blondal	NIL BME	NIL
11	Sg Kelugos HC	MCH	Lux Blondal	BME24399	NIL
12	Telisai HC	PHC	Lux Blondal	24458	VT1804000116
13	Lamunin HC	PHC	Lux Blondal	mac2020 8-8	na
14	Berakas HC	PHC	Lux Blondal	NO BME NO	NO SERIAL NO
15	Berakas HC	PHC	Lux Blondal	NO BME NO	VT180400004
16	Berakas HC	PHC	Lux Blondal	NO BME NO	VT1804000082
17	Berakas HC	PHC	Lux Blondal	NO BME NO	VT1804000223
18	Berakas HC	PHC	Lux Blondal	NO BME NO	VT1804000173
19	Berakas HC	PHC	Lux Blondal	NO BME NO	VT1306001328
20	Berakas HC	PHC	Lux Blondal	NO BME NO	VT1804000206
21	Berakas HC	GEN SIDE ROOM 17	Lux Blondal	NO BME NO	VT1306001386
22	Berakas HC	PHC	Lux Blondal	NO BME NO	VT184000158
23	Berakas HC	PHC	Lux Blondal	NO BME NO	VT1804000190
24	Berakas HC	PHC	Lux Blondal	NO BME NO	VT1804000143
25	Berakas HC	PHC	Lux Blondal	NO BME NO	VT1804000204
26	Berakas HC	PHC	Lux Blondal	NO BME NO	VT1804000108
27	Berakas HC	PHC	Lux Blondal	NO BME NO	VT1804000115
28	Pengkalan Batu HC	PHC	Lux Blondal	NIL	VT1804000005
29	Pengkalan Batu HC	PHC	Lux Blondal	NIL	VT1306001373
30	Pengkalan Batu HC	PHC	Lux Blondal	NIL	VT1306001327
31	Pengkalan Batu HC	PHC	Lux Blondal	NIL	VT1804000229
32	Pengkalan Batu HC	Dental clinic	Lux Blondal	22953	TIDAK ADA

FORM TO BE USED FORM B

TAWARAN SEBUTHARGA
JABATAN PERKHIDMATAN KESIHATAN

Rujukan Tawaran: **36/QTN/JPK/2026**

Nama Tawaran:

SUPPLY, DELIVERY, SERVICE AND INSTALLATION OF THIRTY-TWO (32) UNITS OF FILTER CARTRIDGE FOR LUX BLONDAL AIR PURIFIER AT VARIOUS HEALTH CENTRES, HEALTH SERVICES DEPARTMENT, MINISTRY OF HEALTH

SPECIFICATIONS		YES	NO	IF 'NO' PLEASE STATE ALTERNATIVE OFFER
STANDARD FEATURES	SUPPLY AND INSTALL THIRTY-TWO (32) UNITS OF FILTER CARTRIDGE FOR LUX BLONDAL AIR PURIFIER			
	THE SCOPE OF WORK THAT ARE ASSIGNED SHOULD BE DONE BY TRAINED SERVICE PERSONEL WITH PROPER PROCEDURE AND WEARING PROPER PPE FOR SAFETY AND INFECTION CONTROL PURPOSES.			
	TO SERVICE/REPLACE PRE-FILTER			
	TO INSTALL NEW HEPAFILTER			
	AUTHENTIC HEPAFILTER ORIGINALLY FROM LUX BLONDAL			
	TO CARRYOUT TESTING AIR PURIFIER AFTER INSTALLATION OF HEPAFILTER CARTRIDGE			
	TO VERIFY AIR PURIFIER WORKING NORMALLY			

FORM TO BE USED FORM B

PROCUREMENT REQUIREMENT	
Brand/ Model	
Country of origin	
Price per unit	
Total price	
Delivery period	
Price Validity	
Sample & Brochure	
Warranty	